

DRINKING WATER NOTICE

Roaming Shores Village PWS Has Levels of Trihalomethanes, total Above Drinking Water Standards

Our water system recently violated the maximum contaminant level (MCL) for Trihalomethanes, total (TTHM). The sample(s) collected on May 8, 2007 show TTHM at 0.071 mg/L. The average level of TTHM over the last year was 0.081 mg/L. The standard for TTHM is 0.080 mg/L.

What Should I Do?

You do not need to use an alternative (e.g., bottled) water supply. However, if you have specific health concerns, consult your doctor.

What Does This Mean?

The levels detected do not pose an immediate risk to your health. However, some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous system, and may have an increased risk of getting cancer.

What Is Being Done?

We are investigating and taking the necessary steps to correct the problem as soon as possible.

Additional information may be obtained by contacting Roaming Shores Village PWS at:

Contact Person: Lawrence (Rocky) Pinkert

Phone Number: 440-563-3520

Mailing Address: P.O. Box 237 Roaming Shores Ohio 44084

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

PWS ID: OH0400611

Date Distributed: 24 Nov 08